

**STRUCTURAL CALCULATIONS**

**FOR**

**WESTMORELAND CAMPUS MU  
1717 CITY VIEW STREET  
EUGENE, OREGON 97402**

**November 6, 2020**



**DESIGN PARAMETERS: 2019 Oregon Structural Specialty Code**

**WIND**

BASIC WIND SPEED ..... 98 mph (Ult)  
EXPOSURE ..... B

**SEISMIC**

MAPPED RESPONSE .....  $S_s = 0.721, S_1 = 0.411$   
SITE CLASS ..... D  
IMPORTANCE .....  $I_E = 1.00$

**CONTENTS:**

CALCULATIONS ..... 1 to 7




OSHDPD

# 20179 - Westmoreland Campus MU

1717 City View St, Eugene, OR 97402, USA

Latitude, Longitude: 44.04088, -123.1271349



|                                       |                                  |
|---------------------------------------|----------------------------------|
| <b>Date</b>                           | 10/7/2020, 10:27:27 AM           |
| <b>Design Code Reference Document</b> | ASCE7-16                         |
| <b>Risk Category</b>                  | II                               |
| <b>Site Class</b>                     | D - Default (See Section 11.4.3) |

| Type            | Value                    | Description   |
|-----------------|--------------------------|---|
| S <sub>S</sub>  | 0.721                    | MCE <sub>R</sub> ground motion. (for 0.2 second period) |
| S <sub>1</sub>  | 0.411                    | MCE <sub>R</sub> ground motion. (for 1.0s period)       |
| S <sub>MS</sub> | 0.882                    | Site-modified spectral acceleration value               |
| S <sub>M1</sub> | null -See Section 11.4.8 | Site-modified spectral acceleration value               |
| S <sub>DS</sub> | 0.588                    | Numeric seismic design value at 0.2 second SA           |
| S <sub>D1</sub> | null -See Section 11.4.8 | Numeric seismic design value at 1.0 second SA           |

| Type             | Value                    | Description   |
|------------------|--------------------------|---|
| SDC              | null -See Section 11.4.8 | Seismic design category   |
| F <sub>a</sub>   | 1.223                    | Site amplification factor at 0.2 second   |
| F <sub>v</sub>   | null -See Section 11.4.8 | Site amplification factor at 1.0 second   |
| PGA              | 0.343                    | MCE <sub>G</sub> peak ground acceleration   |
| F <sub>PGA</sub> | 1.257                    | Site amplification factor at PGA  |
| PGA <sub>M</sub> | 0.431                    | Site modified peak ground acceleration  |
| T <sub>L</sub>   | 16                       | Long-period transition period in seconds  |
| SsRT             | 0.721                    | Probabilistic risk-targeted ground motion. (0.2 second)                                   |
| SsUH             | 0.827                    | Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration  |
| SsD              | 1.5                      | Factored deterministic acceleration value. (0.2 second)                                   |
| S1RT             | 0.411                    | Probabilistic risk-targeted ground motion. (1.0 second)                                   |
| S1UH             | 0.478                    | Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration. |
| S1D              | 0.68                     | Factored deterministic acceleration value. (1.0 second)                                   |
| PGAd             | 0.564                    | Factored deterministic acceleration value. (Peak Ground Acceleration)                     |
| C <sub>RS</sub>  | 0.871                    | Mapped value of the risk coefficient at short periods                                     |

10/21/2020

**WESTMORELAND SCHOOL RTU WEIGHTS**

| Unit Tag | Base Weight of unit & accessories (lbs) | + Standard unit Curb (lbs) | xAdaptor Curb (lbs) Safety Factor of 1.5 | xAdaptor Curb (lbs) Safety Factor of 2 | = | Range of Unit TOTAL WEIGHT plus adaptor curb S.F (lbs) |      |
|----------|---|----------------------------|--|--|---|--|------|
| HV-2     | 1634                                    | 180                        | 270                                      | 360                                    |   | 1904   | 1994 |
| HV-3     | 686                                     | 115                        | 172.5                                    | 230                                    |   | 859  | 916  |
| HV-4     | 1312                                    | 143                        | 214.5                                    | 286                                    |   | 1527   | 1598 |
| HV-5     | 1085                                    | 143                        | 214.5                                    | 286                                    |   | 1300   | 1371 |
| HV-6     | 604                                     | 115                        | 172.5                                    | 230                                    |   | 777  | 834  |
| HV-7     | 1312                                    | 143                        | 214.5                                    | 286                                    |   | 1527   | 1598 |
| HV-8     | 1312                                    | 143                        | 214.5                                    | 286                                    |   | 1527   | 1598 |
| HV-9     | 604                                     | 115                        | 172.5                                    | 230                                    |   | 777  | 834  |
| HV-10    | 1612                                    | 180                        | 270                                      | 360                                    |   | 1882   | 1972 |



Job Name: Westmoreland Campus MU

Job No: 20179

Sheet No: 3/7

Client: R&W Engineering

Date: Nov 2020

By: MS

Mech Unit = HV-2  
 Unit Weight = 1634 lbs  
 Unit Height = 4.50 ft  
 Length = 5.92 ft  
 Width = 4.33 ft  
 Curb Weight = 270 lbs  
 Curb Height = 1.17 ft

**WIND DESIGN PER ASCE 7-16, SECTION 26 - 31**  
**Design Wind Loads on Other Structures: 29.5.1**

$A_f = 33.1 \text{ ft}^2$  MU dimension normal wind direction  
 $A_f = 40.0 \text{ ft}^3$  MU+curb dimension normal wind direction  
 GCr = 1.9 Gust Effect Factor  
 V = 98 mph Basic Wind Speed (per Figure 26.5 or local code)  
 K<sub>d</sub> = 0.9 Wind Directionality Factor per Table 26.6  
 K<sub>z</sub> = 0.66 Table 29.3-1 (exposure B)  
 K<sub>zt</sub> = 1.00 Topographic Factor per 26.8-2:  
 $q_z = 14.6 \text{ psf}$  Velocity Pressure  $q_z = 0.00256K_zK_{zt}K_dV^2$

*Design wind force EQ. (29.5-2)*

$F_{ult} = 919 \text{ lbs}$  Force on MU  
 $F_{asd} = 551 \text{ lbs}$   
  
 $F_{ult} = 1111 \text{ lbs}$  Force on MU+curb  
 $F_{asd} = 666 \text{ lbs}$

**SEISMIC DESIGN PER ASCE 7-16, SECTION 13.0**  
**Seismic Design Force: 13.3.1**

$S_{DS} = 0.588 \text{ g}$  NEHRP Seismic Design Provisions  
 $a_p = 2.5$  Component Amplification Factor per Table 13.5.1 or 13.6.1  
 $I_p = 1$  Importance Factor per section 13.1.3  
 $W_p = 1904 \text{ lbs}$  Component Operating Weight  
 $R_p = 6$  Component Response Mod. Factor per Table 13.5.1 or 13.6.1  
 $z/h = 1.00$  Height of attachment with respect to base  
  
 $F_{pult} = 560 \text{ lbs}$  Design Seismic force EQ. (6-13-1)  
 $F_{p asd} = 392 \text{ lbs}$   
  
 $F_{pMIN} = 240 \text{ lbs}$  Design Seismic force EQ. (6-13-3)

Job Name: **Westmoreland Campus MU**  
 Client: **R&W Engineering**

 Job No: **20179**      Sheet No: **4/7**  
 Date: **Nov 2020**      By: **MS**
**Finding Center of Gravity of Total Weight**

|       |              |                                   |       |
|-------|--------------|-----------------------------------|-------|
|       |              | Anchor Center to Center (IN)      | 52.0  |
|       |              | DISTANCE TO CENTER OF WEIGHT (IN) |       |
| HV-2  | WEIGHTS (LB) |                                   |       |
|       | 1634         |                                   | 27.00 |
| Curb  | 270          |                                   | 7.00  |
| Total | 1904         |                                   |       |
|       | y BAR        |                                   | 34.0  |
|       | X BAR        |                                   | 26.0  |

**Finding Seismic Force,  $F_p$  (Per ASCE 7 - 13.3)**

|                       |              |
|-----------------------|--------------|
| latitude              | 44.04088     |
| longitude             | -123.1271349 |
| I (Importance Factor) | 1            |
| $a_p$ (               | 2.5          |
| $R_p$ (               | 6            |
| $S_s$                 | 0.721        |
| $S_1$                 | 0.411        |
| $F_a$                 | 1.2          |
| $S_{DS}$              | 0.588        |
| z                     | 1            |
| h                     | 1            |

|                       |      |
|-----------------------|------|
| Seismic Weight, $W_p$ | 1904 |
|-----------------------|------|

|              |       |                    |
|--------------|-------|--------------------|
| $F_p$ (lb) = | 391.8 | ASCE 7 (EQ.13.3-1) |
|--------------|-------|--------------------|

|                  |       |                    |
|------------------|-------|--------------------|
| $F_p$ min (lb) = | 239.9 | ASCE 7 (EQ.13.3-3) |
|------------------|-------|--------------------|

|                  |         |                    |
|------------------|---------|--------------------|
| $F_p$ max (lb) = | 1,279.5 | ASCE 7 (EQ.13.3-2) |
|------------------|---------|--------------------|

|                                     |       |
|-------------------------------------|-------|
| <b>Design <math>F_p</math> (lb)</b> | 391.8 |
|-------------------------------------|-------|

**Anchor Force Seismic**

|                                      |        |
|--------------------------------------|--------|
| $M_{RESIST}$ (LB*FT) Strength Design | 2475.2 |
| $M_{o.T}$ (LB*FT) Strength Design    | 1110.2 |


|        |         |                       |               |
|--------|---------|-----------------------|---------------|
| T (lb) | -314.99 | <b>No Overturning</b> | At Back Side  |
| T (lb) | -314.99 | <b>No Overturning</b> | At Front Side |

**Anchor Design Seismic\***

| (2) Back Anchors | Force Per Anchor | (2) Front Anchors | Force Per Anchor |
|------------------|------------------|-------------------|------------------|
| T/Anchor         | 0.00             | T/Anchor          | 0.00 LB          |
| V/Anchor         | 97.96            | V/anchor          | 97.96 LB         |

**Anchor Design Wind\***

| (2) Back Anchors | Force Per Anchor | (2) Front Anchors | Force Per Anchor |
|------------------|------------------|-------------------|------------------|
| T/Anchor         | 0.00             | T/Anchor          | 0.00 LB          |
| V/Anchor         | 166.60           | V/anchor          | 166.60 LB        |

**WIND**

 width = 4.33 ft  
 $F_{RES}$  = 1904 lbs  
 $F_{OT}$  = 666 lbs

$$M_{RES} = 2475.2 \text{ lbs-ft} \quad *ASD$$

$$M_{OT} = 1888.2 \text{ lbs-ft} \quad *ASD$$

$$T_{wind} = -135.47 \text{ lbs}$$

$$V_{wind} = 666 \text{ lbs}$$

**NO OVERTURNING**
**WIND CONTROLS**

\*USE SIMPSON 1/4" DIA x 2 1/2 SDS SCREW IN EACH CORNER



**COMPANY**  
 WDY, Inc.  
 6443 SW Beaverton-Hillsdale Hwy  
 Suite 210  
 Portland, OR 97221  
 Nov. 5, 2020 16:25


**PROJECT**  
 20179  
 Westmoreland Campus MU  
 (E) 2x10 @ 24 O.C.wwb

**Design Check Calculation Sheet**  
 WoodWorks Sizer 2019 (Update 1)

**Loads:**

| Load     | Type | Distribution | Pat-tern | Location [ft] |      | Magnitude |         | Unit |
|----------|------|--------------|----------|---------------|------|-----------|---------|------|
|          |      |              |          | Start         | End  | Start     | End     |      |
| DL       | Dead | Full Area    |          |               |      | 8.00      | (24.0") | psf  |
| SL       | Snow | Full Area    |          |               |      | 25.00     | (24.0") | psf  |
| HV-4/7/8 | Dead | Partial UDL  |          | 0.00          | 6.00 | 127.0     | 127.0   | plf  |

**Maximum Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :**



|             |      |  |      |
|-------------|------|--|------|
| Unfactored: |      |  |      |
| Dead        | 699  |  | 268  |
| Snow        | 321  |  | 322  |
| Factored:   |      |  |      |
| Total       | 1020 |  | 590  |
| Bearing:    |      |  |      |
| Capacity    |      |  |      |
| Joist       | 5156 |  | 5156 |
| Support     | 6445 |  | 6445 |
| Des ratio   |      |  |      |
| Joist       | 0.20 |  | 0.11 |
| Support     | 0.16 |  | 0.09 |
| Load comb   | #2   |  | #2   |
| Length      | 5.50 |  | 5.50 |
| Min req'd   | 1.09 |  | 0.63 |
| Cb          | 1.00 |  | 1.00 |
| Cb min      | 1.00 |  | 1.00 |
| Cb support  | -    |  | -    |
| Fcp sup     | 625  |  | 625  |

Bearing for wall supports is perpendicular-to-grain bearing on top plate. No stud design included.

**Lumber-soft, D.Fir-L, No.2, 2x10 (1-1/2"x9-1/4")**

Supports: All - Lumber Stud Wall, D.Fir-L Stud  
 Roof joist spaced at 24.0" c/c; Total length: 12.85'; Clear span: 11.928'; Volume = 1.2 cu.ft.  
 Lateral support: top = continuous, bottom = at supports; Repetitive factor: applied where permitted (refer to online help);  
**This section PASSES the design code check.**

**Analysis vs. Allowable Stress and Deflection using NDS 2018 :**

| Criterion    | Analysis Value | Design Value | Unit | Analysis/Design |
|--------------|----------------|--------------|------|-----------------|
| Shear        | fv = 85        | Fv' = 207    | psi  | fv/Fv' = 0.41   |
| Bending(+)   | fb = 1285      | Fb' = 1309   | psi  | fb/Fb' = 0.98   |
| Dead Defl'n  | 0.21 = L/672   |              |      |                 |
| Live Defl'n  | 0.15 = L/977   | 0.60 = L/240 | in   | 0.25            |
| Total Defl'n | 0.36 = L/398   | 0.80 = L/180 | in   | 0.45            |



**WoodWorks**<sup>®</sup>  
SOFTWARE FOR WOOD DESIGN

**COMPANY**  
WDY, Inc.  
6443 SW Beaverton-Hillsdale Hwy  
Suite 210  
Portland, OR 97221  
Nov. 5, 2020 16:26


**PROJECT**  
20179  
Westmoreland Campus MU  
(E) 2x12 @ 24 O.C.wwb

**Design Check Calculation Sheet**  
WoodWorks Sizer 2019 (Update 1)

**Loads:**

| Load    | Type | Distribution | Pat-tern | Location [ft] |      | Magnitude |         | Unit |
|---------|------|--------------|----------|---------------|------|-----------|---------|------|
|         |      |              |          | Start         | End  | Start     | End     |      |
| DL      | Dead | Full Area    |          |               |      | 8.00      | (24.0") | psf  |
| SL      | Snow | Full Area    |          |               |      | 25.00     | (24.0") | psf  |
| HV-2/10 | Dead | Partial UDL  |          | 0.00          | 6.00 | 158.6     | 158.6   | plf  |

**Maximum Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :**



|             |      |  |      |
|-------------|------|--|------|
| Unfactored: |      |  |      |
| Dead        | 847  |  | 310  |
| Snow        | 320  |  | 322  |
| Factored:   |      |  |      |
| Total       | 1168 |  | 631  |
| Bearing:    |      |  |      |
| Capacity    |      |  |      |
| Joist       | 5156 |  | 5156 |
| Support     | 6445 |  | 6445 |
| Des ratio   |      |  |      |
| Joist       | 0.23 |  | 0.12 |
| Support     | 0.18 |  | 0.10 |
| Load comb   | #2   |  | #2   |
| Length      | 5.50 |  | 5.50 |
| Min req'd   | 1.25 |  | 0.67 |
| Cb          | 1.00 |  | 1.00 |
| Cb min      | 1.00 |  | 1.00 |
| Cb support  | -    |  | -    |
| Fcp sup     | 625  |  | 625  |

Bearing for wall supports is perpendicular-to-grain bearing on top plate. No stud design included.

**Lumber-soft, D.Fir-L, No.2, 2x12 (1-1/2"x11-1/4")**

Supports: All - Lumber Stud Wall, D.Fir-L Stud

Roof joist spaced at 24.0" c/c; Total length: 12.84'; Clear span: 11.92'; Volume = 1.5 cu.ft.

Lateral support: top = continuous, bottom = at supports; Repetitive factor: applied where permitted (refer to online help);

**This section PASSES the design code check.**

**Analysis vs. Allowable Stress and Deflection using NDS 2018 :**

| Criterion    | Analysis Value | Design Value | Unit | Analysis/Design |
|--------------|----------------|--------------|------|-----------------|
| Shear        | fv = 77        | Fv' = 207    | psi  | fv/Fv' = 0.37   |
| Bending(+)   | fb = 978       | Fb' = 1190   | psi  | fb/Fb' = 0.82   |
| Dead Defl'n  | 0.14 = < L/999 |              |      |                 |
| Live Defl'n  | 0.08 = < L/999 | 0.60 = L/240 | in   | 0.14            |
| Total Defl'n | 0.22 = L/641   | 0.80 = L/180 | in   | 0.28            |



**WoodWorks**<sup>®</sup>  
SOFTWARE FOR WOOD DESIGN

**COMPANY**  
WDY, Inc.  
6443 SW Beaverton-Hillsdale Hwy  
Suite 210  
Portland, OR 97221  
Nov. 6, 2020 13:23


**PROJECT**  
20179  
Westmoreland Campus MU  
HV-3,6 (N) LVL @ 24 O.C.wwb

**Design Check Calculation Sheet**  
WoodWorks Sizer 2019 (Update 1)

**Loads:**

| Load   | Type | Distribution | Pat-tern | Location [ft] |      | Magnitude |         | Unit |
|--------|------|--------------|----------|---------------|------|-----------|---------|------|
|        |      |              |          | Start         | End  | Start     | End     |      |
| DL     | Dead | Full Area    | No       |               |      | 8.00      | (24.0") | psf  |
| SL     | Snow | Full Area    | No       |               |      | 25.00     | (24.0") | psf  |
| HV-3/9 | Dead | Partial UDL  | No       | 3.50          | 9.50 | 72.0      | 72.0    | plf  |

**Maximum Reactions (lbs), Bearing Capacities (lbs) and Bearing Lengths (in) :**



|             |      |  |        |  |
|-------------|------|--|--------|--|
| Unfactored: |      |  |        |  |
| Dead        | 379  |  | 347    |  |
| Snow        | 382  |  | 540    |  |
| Factored:   |      |  |        |  |
| Total       | 761  |  | 887    |  |
| Bearing:    |      |  |        |  |
| Capacity    |      |  |        |  |
| Joist       | 7219 |  | 1369   |  |
| Support     | 7305 |  | 887    |  |
| Des ratio   |      |  |        |  |
| Joist       | 0.11 |  | 0.65   |  |
| Support     | 0.10 |  | 1.00   |  |
| Load comb   | #2   |  | #2     |  |
| Length      | 5.50 |  | 0.67   |  |
| Min req'd   | 0.58 |  | 0.67** |  |
| Cb          | 1.00 |  | 1.56   |  |
| Cb min      | 1.00 |  | 1.56   |  |
| Cb support  | -    |  | 1.21   |  |
| Fcp sup     | 625  |  | 625    |  |

\*\*Minimum bearing length governed by the required width of the supporting member.  
Bearing for wall supports is perpendicular-to-grain bearing on top plate. No stud design included.

*(WORST CASE)  
OK Y.*

**LVL n-ply, 2.0E, 2500Fb, 1-3/4"x9-1/4", 1-ply**

Supports: 1 - Lumber Stud Wall, D.Fir-L Stud; 2 - Lumber n-ply Beam, D.Fir-L No.2;  
Roof joist spaced at 24" c/c; Total length: 18.43'; Clear span: 14.948', 2.972'; Volume = 2.1 cu.ft.  
Lateral support: top = continuous, bottom = at supports; Repetitive factor: applied where permitted (refer to online help);  
**This section PASSES the design code check.**

**Analysis vs. Allowable Stress and Deflection using NDS 2018 :**

| Criterion     | Analysis Value | Design Value | Unit | Analysis/Design |
|---------------|----------------|--------------|------|-----------------|
| Shear         | fv = 63        | Fv' = 328    | psi  | fv/Fv' = 0.19   |
| Bending(+)    | fb = 1420      | Fb' = 3098   | psi  | fb/Fb' = 0.46   |
| Bending(-)    | fb = 143       | Fb' = 1380   | psi  | fb/Fb' = 0.10   |
| Deflection:   |                |              |      |                 |
| Interior Dead | 0.27 = L/660   |              |      |                 |
| Live          | 0.22 = L/807   | 0.75 = L/240 | in   | 0.30            |
| Total         | 0.50 = L/363   | 1.00 = L/180 | in   | 0.50            |
| Cantil. Dead  | -0.16 = L/227  |              |      |                 |
| Live          | -0.13 = L/279  | 0.30 = L/120 | in   | 0.43            |
| Total         | -0.29 = L/125  | 0.40 = L/90  | in   | 0.72            |