



GENERAL NOTES:
A. PROTECT & PRESERVE ADJACENT (E) FINISHES TO REMAIN FROM DAMAGE CAUSED BY DEMOLITION & CONSTRUCTION. CONTRACTOR TO REPAIR INCIDENTAL DAMAGE AT OWN EXPENSE.
B. HVAC CONTROLLERS ARE TO BE REUSED AND RELOCATED PER THE MECHANICAL PLANS.

- KEYED NOTES:
1 REMOVE RETURN REGISTER AND CAP DUCT AT CEILING PENETRATION.
2 REMOVE RETURN REGISTER AND FIRE DAMPER INTO MECH AIR PLENUM WALL.
3 DISCONNECT AND REMOVE EF-3. PATCH ROOF AND CEILING PENETRATIONS.

- LEGEND:
(E) = EXISTING
(RL) = RELOCATED
(N) = NEW
[Hatched Box] = DUCT SYSTEM TO BE REMOVED
[Line with T] = VOLUME DAMPER
[Circle with T] = FIRE DAMPER
[Circle with T] = THERMOSTAT
[Circle with T] = POINT OF CONNECTION
[Symbol] = TAG #
[Symbol] = THROW PATTERN
[Symbol] = NECK SIZE
[Symbol] = CFM

HVAC DEMOLITION PLAN
1/4" = 1'-0"

ISSUED FOR CONSTRUCTION

EVERGREEN ENGINEERING, INC.
Engineering and Construction Services
ATLANTA, GEORGIA (404) 887-1471
EVERETT, WASHINGTON (888) 484-4771
EUGENE, OREGON (541) 484-4771
www.evergreenengineering.com

CLIENT: INSPIRED ARCHITECTURE
LOCATION: 1200 HWY 99 N. EUGENE, OR 97402

TITLE: LANE ESD - REMODEL
MEP DEPT.
HVAC DEMOLITION PLAN

DRAWING # 1000M01
JOB # 4366.0

REV: 0
DATE: 6-10-22

DESIGN: PLS
DRAWN: CJS
CHECK: []

DATE: 6-10-22

DATE: 6-10-22

REV	BY	APPD	DATE	DESCRIPTION
0	CJS	PLS	7/7/22	ISSUED FOR CONSTRUCTION